

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

VOLUME- II

(Tender Specification: WESCO/CEO/019)
GROUP-L

[Detail Scope of Supply]
ANNEXURE

Date: 11.09.2007

VOLUME-II DSS	Specification : WESCO/CEO/019, 07-08
---------------	--------------------------------------

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

TENDER DOCUMENT FOR
GROUP- L ITEMS
SPECIFICATION FOR GROUP-L ITEMS

ELECTRICAL EQUIPMENTS & INSTRUMENTS	QUANTITY
Chain Pulley Block 1 Ton	10 No
Chainpulley Block 2 Ton	10 No
Chainpulley Block 3 Ton	5 No
Chainpulley Block 5 Ton	5 No
Single Seave pulley 1 Ton	20 No
Double Seave pulley 2 Ton	20 No
Pulling & Lifting m/c 3 Ton	10 no
Pulling & Lifting m/c 5 Ton	15 no
Snatch pulley	10 no
Hydraulic Jack [5 Ton]	6 no
Insulation Megger (1 KV, 0-2000 Mohm), Analog type, Hand driven. (with Testing lead & Carrying case)	3 No
Insulation Megger (2.5 KV, 0-5000 Mohm) Analog type, Hand driven.(with Testing lead & Carrying case)	6 No
Earth Megger: Analog type, Hand driven. Range: 0-100 ohm confirms to IS: 9223: 1979 alongwith Earth testing kits consists of M.S Spikes, Rolls of flexible wire, Hammer, Plier and Screw driver Housed in a canvas bag.	09 Set
Digital Clamp On Meter/ Tongue Tester: Range:-1000 Amp A.C, LCD Display, Data hold to freeze the displayed value complete with test lids.	30 No

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

Crimping Tool [25 mm to 400 mm die]	15 No
Crimping Tool [25 mm to 400 mm die less]	6 No
Drill machine suitable upto 25 mm drill	2 No
Slide Wrench 20-32 mm [ply]	20 No
Plier 8"	200 No
Line Man Tool Kit: of good quality having provision of i) Tester ii) Plier (8") iii) Screw Driver (One 12") iv) Screw Driver (One 8") V) Slide wrench, V) Torch Light (2 Cell) All these are to be housed in a bag. The tool kit should have separate case for hand gloves.	200 Set