

**Clarification/Correction to the Tender Notification CSO/03/ Distribution Transformer Dt.29.02.2008**

Following clauses of above Tender published in our Web Site may be read as follows.

1. Page No. -20 of 66 – Clause 18.02 ( Liquidity Damage) :-  
May be read as Ten Percent of the contract price instead of Five percent of the contract price.
2. Annexure III – Price Schedule for Goods offered :- Unit is Number instead of In KM.
3. Page No. 25 – Clause 1 of Technical Specification for 100 KVA : The Phrase “Three Star Rating” stands deleted.
4. Annexure VI – Past Performance Details format table is modified.
5. As per Clause No. 6.8 (C) of Technical Specification for 315 kVA and 500 kVA Distribution Transformers it was mentioned that the radiators shall provide only on HV side and of FIN type. The same is amended as following :-

”Radiators may be provided on LV side in addition to HV side; however sufficient space to be maintained for smooth operation & maintenance of LT bushing”.