

**TENDER NOTIFICATION NO. : CSO/06/LT CABLE & DIST. BOX DTD. 16.06.08  
REVISED DUE DATE FOR SUBMISSION OF OFFER : 10.07.08**

**MODIFICATION IN TECHNICAL SPECIFICATION**

**Clause No. 7.0 ARMOURING : (Page No. 25)**

The above clause should be read as :

**Cable size 1C x 35 mm<sup>2</sup> and 1C x 70 mm<sup>2</sup> shall be unarmoured and the balance sizes shall be with armoured.**

**Armouring shall be Aluminum Round Wire. The method, type, dimensions, joints, conductance etc. of armour shall confirm to IS 7098.**