

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

VOLUME- II

(Tender Specification: WESCO/CEO/021)
GROUP-C

[Detail Scope of Supply]
ANNEXURE

Date: 27.09.2008

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

TENDER DOCUMENT FOR SUPPLY OF
GROUP- C ITEMS

SPECIFICATION FOR GROUP- C ITEMS

<u>LT GI PIN</u>	Quantity
LT G.I Pin Conforming to as per REC construction standard & IS: 2486 (Part - 1)/1993, 2 nd Revision with its relevant latest amendments & as per drawing provided.	397 no.

L.T G.I. STRAP WITH Bolts & Nuts	Qty
LT G.I Straps with bolts consisting a pair of straps of size : 185x30x3 mm with two number of bolts of size : 115x12 mm with hexagonal nut and spring washer of 3 mm thick as per REC Construction standard conforming to IS : 7935/1975, Amendment-3, Reaffirmed 1991..	441 pair

CI KNOB	Quantity
C.I Knob conforming to REC Construction standard.	21 no.

33 Kv Hardware Fittings (B&S Type)	Quantity
33 KV Hardware Fittings (B & S) Type: 33 Kv Hard wear fittings (B & S type) suitable for overhead power line Conforming to IS: 2486 (Part I)/1993, (2 nd Revision), 2486 (Part – II)/1989(2 nd Revision), 2486 (Part III)/1974., 2486 (Part – IV)/1981, Reaffirmed – 1991.	674 No

<u>33 KV GI PIN</u>	Quantity
---------------------	----------

VOLUME-II DSS	Specification : WESCO/CEO/021, 08-09
---------------	--------------------------------------

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

33 Kv G.I Pin Conforming to IS: 2486 (Part - 1)/1993, 2 nd Revision with its relevant latest amendments & as per drawing provided.	500 No.
---	---------

HT Stay Set for 33 kv System	Quantity
H.T Stay sets suitable for 33 kv. System as per enclosed Drawings, consisting of stay rod, Anchor plate, single bow down buckle with hot-dipped Galvanisation done as per IS: 2629/1985 (1 st Revision), (Amendment-2) & IS: 4736/1968 (1 st Revision),(Amendment-1) for Hot-dipped Zinc Coating.	100 No.