

TENDER NOTIFICATION NO. : CSO/13/Distribution transformerl DTD.07.11.08

DUE DATE FOR SUBMISSION OF OFFER : 22.11.08

MODIFICATION IN Section-II , Technical Specification

1. Clause No.6.5(Technical Specification of 25 kva,11kv/433V) Impedance Value-The percentage impedance value 25 kva is 4.5%.

2. Clause No.6.6(Technical Specification of 63,100Kva,33kv/433V) Impedance Value-The percentage impedance value is 4.50%for 63 KVA.

3. Clause No.6.3(Technical Specification of 100Kva,33kv/433V)
Tap range from +5% to -5% with 2.5% in each step. i.e.
Tap1: +5%
Tap2 : +2.5%
Tap3 : 0%
Tap4 : -2.5%
Tap5 : -5%